

**Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,**  
STRUCTURAL ENGINEER, CHARTERED ENGINEER  
REGISTERED&APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Ref: Collector, Kpm, Lr. No: RC 23640/2011/M1 Dated 19.05.2012

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakkonam – 631002  
Off: #4, Vanthavasi Road,  
Gandhi nagar,  
Kanchipuram - 631501  
Cell: 9443106470, 8056631312  
Email : dnatarajan8@gmail.com

**STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL**  
**STATEMENT ACCOMPANYING FORM – A**

1. Name of the School and Door no of the Building : **SRI SANKARA VIDYALAYA**  
1<sup>st</sup> Main Road, Sri Sankara Nagar, Pammal, Pallavaram Taluk,  
Chengalpattu District, Chennai – 603 103
2. Location (street No. Ward No. Name of place, ie., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment) : S.F. No. 142 & 143/1  
1<sup>st</sup> Main Road, Sri Sankara Nagar,  
Pammal, Pallavaram Taluk  
Chengalpattu District, Chennai – 600 075
3. Year of construction : Ground Floor : RCC : 1987; First Floor : RCC : 1997  
Second & Third Floor : RCC : 2001
4. Approximates cost of construction as per current rate : Rs. 170.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : Educational
6. Purpose for which the building has hitherto been used : Educational
7. Details of construction of the building (particulars of the foundation, soil, Specification of various parts under  
(i) Foundation : RCC Framed Structure  
(ii) Basement : RCC Column & Footing  
(iii) Superstructure : RCC Column, Plinth Beam & Brick in CM  
(iv) Floor & Roof are to be given) : RCC Column & Brick in CM  
: Flooring: Cement & Tiles  
Roof: RCC Slab
8. Period for which the license is require : May be issued FROM 01.09.2024 to 31.08.2027  
(For Three Years only)
9. Number of persons to be accommodated Refer ANNEXURE to this : Three Thousand Five Hundred (3500) Pupils only

Place : Kancheepuram

Date : 23-04-2024

Signature of the Correspondent

Signature of the Engineer

Er. D. NATARAJAN, B.E.,(CIVIL) MIE  
Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.  
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.




மழை பெறுவோம்

ANNEXURE TO "STATEMENT ACCOMPANYING FORM – A"

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of the building originally is change or altered subsequently.

This is further to certify that no thatched buildings are used for conducting any classes within the School premises. Any thatched building constructed/used after issue of this certificate, I would be held responsible for fire accident/mishap that may occur later and that I am aware that it is a punishable crime.



Signature of the Correspondent

**.NATARAJAN, B.E.(CIVIL),M.I.E.,**  
STRUCTURAL ENGINEER, CHARTERED ENGINEER  
REGISTERED&APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakkonam - 631002  
Off: #4, Vanthavasi Road,  
Gandhi nagar,  
Kanchipuram - 631501  
Cell: 9443106470, 8056631312  
Email : dnatarajan8@gmail.com

**FORM - B**

**STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

**SRI SANKARA VIDYALAYA, PAMMAL, CHENNAI**

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (B) OF SECTION OF (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING ( LICENSING ACT 1965 TAMIL NADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features.

**1. Foundation:**

- |  |                   |
|--|-------------------|
| i. Depth below ground level                          | : 08ft below G.L  |
| ii. Nature of soil met out in the foundation         | : Hard Soil       |
| iii. Pressure at foundation                          | : 12 tones / Sq.m |
| iv. Probable safe bearing capacity of the foundation | : 20 tones / Sq.m |

**2. Superstructure:**

- |   |  |
|---|--|
| i. Maximum stress in most critical Sections of masonry and concrete | a) R.C.C Concrete : 35 Kg / Sq.cm<br>b) Masonry : 07 tones / Sq.m. |
| ii. Nature of masonry and concrete And its safe permissible stress  | : Brick masonry in cm: 30 tones / Sq.m.<br>R.C.C : 40 Kg / Sq.cm.  |

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from **01.09.2024 to 31.08.2027**.

  
Signature of the Correspondent

  
Signature of the Engineer  
Er. D. NATARAJAN, B.E., (CIVIL), M.I.E.  
Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.  
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

**D. NATARAJAN, B.E.(CIVIL),M.I.E.,**  
STRUCTURAL ENGINEER, CHARTERED ENGINEER  
REGISTERED & APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS 1A, KANCHEEPURAM DISTRICT

Res: 50-A, 3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakkonam - 631002  
Off: #4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631501  
Cell: 9443106470, 8056631312  
Email: dnatarajan8@gmail.com

**FORM - C**

**STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

**SRI SANKARA VIDYALAYA, PAMMAL, CHENNAI**

Form of certificate of structural soundness under sub section (b) of section of 4 of the Madras Public Buildings (Licensing Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public Building (Licensing) rules 1977.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
<b>SRI SANKARA VIDYALAYA</b> 1 <sup>st</sup> Main Road, Sri Sankara Nagar, Pammal, Pallavaram Taluk, Chengalpattu District, Chennai - 600 075	<b>Ground Floor :</b> RCC : 36 Years <b>First Floor :</b> RCC : 26 Years <b>Second &amp; Third Floors :</b> RCC : 22 Years	Rs. 170.00 Lakhs	Ground Floor + 3	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational Purpose	License may be issued for the period of Three Years from 01.09.2024 to 31.08.2027	3500 Pupils only	Building is structurally sound

Signature of the Correspondent

Signature of the Engineer

**Er. D. NATARAJAN, B.E.,(CIVIL),M.I.E.**  
Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.  
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

**D.NATARAJAN, B.E.(CIVIL),M.I.E.,**  
STRUCTURAL ENGINEER, CHARTERED ENGINEER  
REGISTERED & APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakkonam - 631002  
Off: #4, Vanthavasi Road,  
Gandhi nagar,  
Kanchipuram - 631501  
Cell: 9443106470, 8056631312  
Email : dnatarajan8@gmail.com

**FORM - E**

**STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS**  
**SRI SANKARA VIDYALAYA, PAMMAL, CHENNAI**

Form of report to be made to the competent authority by inspecting authorities or officers appointed under other acts under section 28 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) referred to in rule 7 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.

1. Name and Designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law. : **Er. D.NATARAJAN, B.E. (CIVIL), M.I.E.**  
**CHARTERED ENGINEER**  
**REGISTERED & APPROVED ENGINEER**  
**BY THE BOARD OF ENGINEERS, TAMILNADU.**  
**PANEL ENGINEER CLASS IA,**  
**KANCHEEPURAM DISTRICT**
2. Location of the building inspected (Door Number, Street Number, Name of place, i.e. Municipal Corporation / Municipality / Panchayat or Panchayat Union/Township/Cantonment.) : S.F.No. 142 & 143/1,  
1<sup>st</sup> Main Road, Sri Sankara Nagar,  
Pammal, Pallavaram Taluk,  
Chengalpattu District, Chennai - 600 075
3. Date of Inspection : 23-04-2024
4. Purpose for which the building is used : Educational Purpose
5. Nature of defects noticed : No defects found
6. Suggestions for rectifying defects : Nil
7. If in a dangerous condition, immediate : Nil

**Signature of the Engineer**

**Er. D. NATARAJAN, B.E.,(CIVIL) MIE**  
Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.  
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

**BUILDING SAFETY CERTIFICATE**

No. 08/PE-KANCHEEPURAM

Dated : 23.04.2024

Certified that the **SRI SANKARA VIDYALAYA**, 1<sup>st</sup> Main Road, Sri Sankara Nagar, Pammal, Pallavaram Taluk, Chengalpattu District, Chennai – 600 075, Comprised of **Ground, First, Second & Third Floors** owned / occupied by **SRI SANKARA VIDYALAYA** have complied with the Building Bye Laws in accordance with rule of State / UT, and incorporate the provisions of building safety as specified in National Building Code 2005, 2016 and as amended thereafter and has been verified by the concerned officer on **23.04.2024** in the presence of **Correspondent, SRI SANKARA VIDYALAYA** and that the said above building / premises is safe and fit for running School with effect from **01.09.2024** for a period of Three years only in accordance with rules.

Issued on **23.04.2024** at **Kancheepuram** by

  
**Signature with Seal :**

Er. D. NATARAJAN, B.E., (CIVIL) MIE  
Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.  
Cell: 94431 06470, 8056631312

To  
**THE CORRESPONDENT**  
**SRI SANKARA VIDYALAYA**  
1<sup>st</sup> Main Road, Sri Sankara Nagar, Pammal,  
Pallavaram Taluk, Chengalpattu District, Chennai – 600 075

**.NATARAJAN, B.E.(CIVIL),M.I.E.,**  
STRUCTURAL ENGINEER, CHARTERED ENGINEER  
REGISTERED&APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakkonam – 631002  
Off: #4, Vanthavasi Road,  
Gandhi nagar,  
Kanchipuram - 631501  
Cell: 9443106470, 8056631312  
Email : dnatarajan8@gmail.com

### **BUILDING COMPLETION CERTIFICATE**

This is to certify that the below mentioned building was completed in all respect as per the prescribed and approved plan, belongs to **SRI SANKARA VIDYALAYA**, 1<sup>st</sup> Main Road, Sri Sankara Nagar, Pammal, Pallavaram Taluk, Chengalpattu District, Chennai – 600 075 as details below.

1. Name of the School and Door No. of the Building : **SRI SANKARA VIDYALAYA**  
1<sup>st</sup> Main Road, Sri Sankara Nagar,  
Pammal, Pallavaram Taluk,  
Chengalpattu District, Chennai – 600 075
2. Location (Street No. Ward No.) Name of Place, i.e. Corporation, Municipality/Panchayat Union/ Panchayat/Township/Cantonment : S.F. No. 142 & 143/1  
1<sup>st</sup> Main Road, Sri Sankara Nagar,  
Pammal, Pallavaram Taluk,  
Chengalpattu District, Chennai – 600 075
3. Nature & Specifications of Building : RCC Framed Structure  
a) R.C.C. 1:2:4 in Column Foundation, Plinth Beam, Roof Beam and Roof Slab etc.  
b) Basement Height – 4'-0"  
c) Brick Work in cm. 1:6  
d) Provided proper R.C.C. 1:2:4 in Roof Slab, Lintel, Beam and Sunshade etc.,  
e) Ceiling Plastering in cm 1:3  
f) Tiles in cm 1:5
4. Amenities Provided : a) Concealed Electrification  
b) Water Supply and Sanitary Arrangement  
c) Septic Tank, Bore Well & OHT, Motor etc.  
d) Stair Case

5. Construction Area of the Building :

<b><u>NAME OF THE BLOCK :</u></b>	<b>Area Scheduled of the Building in Sq. mt.</b>
Ground Floor : RCC : 1987; First Floor : RCC : 1997 Second & Third Floor : RCC : 2001	1727.00 Sq. mt.

6. Documents Reference : Prescribed Plan  
As per Registered Document
7. Future Life of Building : 50 Years

  
Er. D. NATARAJAN, B.E.,(CIVIL) MIE  
Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.  
Cell: 94431 06470, 8056631312